

Answer to item b) Clause 15 of Pre-Bid Meeting MOM

05 November, 2015

<p>In the SLD the wave trap is not mentioned, how can we enable PLC communication of the teleprotection system without wave traps? In case PLC is needed on all lines we will need to supply 24 wave traps (2 per line, 4*220 kV lines and 8*110 kV lines)</p>	<p>The answers to all questions can be found in Bidding Document, page 564 8.19 General Technical Specifications – Requirements for the protections of “Yerevan TPC” CJSC connections. “General requirements for the protections of “Yerevan TPC” CJSC connections”.</p> <p>Note: All information provided in this clause is the terms of reference, provided by the “Electric Power System Operator” CJSC of the Republic of Armenia.</p>
--	---